

CERTIFICATE OF VOC EMISSIONS

USG certifies that the following materials are

Low-Emitting

as measured following the specified requirements of the "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers," including 2004 addendum. Testing showed emissions as passing CHPS requirements at formaldehyde concentration levels below 13.5 ppb. In addition for all other VOCs, these products contribute no more than one-half of the chronic inhalation Reference Exposure Level adopted by California EPA OEHHA for the Proposition 65 chemicals. All emission levels were verified by an approved CHPS third party testing laboratory.

These low-emitting products meet CHPS criteria, the requirements for LEED for School certification and formaldehyde is NOT used in the manufacturing of these products.

COMMERCIAL ACOUSTICAL PANELS:

ASPEN™, ASTRO™ CLIMAPLUS™, ECLIPSE™ CLIMAPLUS™, FISSURED™, MARS™ CLIMAPLUS™, MILLENNIA™ CLIMAPLUS™, OLYMPIA MICRO™ CLIMAPLUS™, PEBBLED™ CLIMAPLUS™, RADAR™, RADAR™ CLIMAPLUS™, ROCK FACE® CLIMAPLUS™, TOUCHSTONE™ CLIMAPLUS™

MICORE™ 160 and MICORE™ 300 mineral fiber board

RETAIL ACOUSTICAL PANELS:

ALPINE™, FIFTH AVENUE™, LUNA™ CLIMAPLUS™, MAJESTIC™ CLIMAPLUS™, MOONSCAPE™ CLIMAPLUS™, SAVILLE ROW™, SUPERPANEL™ CLIMAPLUS™,

Products listed include all item numbers produced regardless of manufacturing locations.



Charles D. Byers, Ph.D., Manager, Product Safety

July 24, 2009

USG Corporation
550 West Adams Street
Chicago, IL 60661