

CERTIFICATE OF VOC EMISSIONS

USG certifies that the following materials are

Zero-Emitting

as measured following the specified requirements of the “Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers,” including 2004 addendum. Testing showed no emissions for all individual VOCs, including formaldehyde, and *all* VOCs with chronic inhalation Reference Exposure Levels adopted by California EPA OEHHA for Proposition 65 chemicals. All emission levels were verified by an approved CHPS third party testing laboratory.

These zero-emitting products do not contribute VOCs/formaldehyde to indoor air and formaldehyde is NOT used in the manufacturing of these products.

COMMERCIAL ACOUSTICAL PANELS:

BRIO™ CLIMAPLUS™, “F” FISSURED™, FRESCO™ CLIMAPLUS™, FROST™, FROST™ CLIMAPLUS™, GLACIER™, SANDRIFT™ CLIMAPLUS™, and SUMMIT™ CLIMAPLUS™

RETAIL ACOUSTICAL PANELS:

ARTIC™ CLIMAPLUS™ and CHEYENNE™

DRYWALL PANELS:

SHEETROCK® brand gypsum panels and FIBEROCK® brand gypsum panels.

Products listed include all item numbers of each product regardless of manufacturing locations.



Charles D. Byers, Ph.D., Manager, Product Safety

July 24, 2009

USG Corporation
550 West Adams Street
Chicago, IL 60661